

Plant Bowen

Prepared by: TETRA TECH

TŁ

Monthly Dewatering Results¹

April 2019

Parameter	Units	Effluent Concentration		Permit Limits	
		Minimum	Maximum	Daily Avg	Daily Max
Flow	MGD	0	0.29	***	***
рН	SU	6.5	7.8	6.0 - 9.0	
Total Suspended Solids	mg/L	12.0	51.0	30.0	100.0
Oil and Grease	mg/L	ND ²	ND	15.0	20.0

Parameter	Units	nits Measured Effluent Concentration				
		4/5/2019	4/9/2019	4/16/2019	4/22/2019	
Turbidity	NTU	1.185	1.8	3.6	5.5	
Total Dissolved Solids	mg/L	1,540	1,900	1,700	1,700	
Ammonia	mg/L	0.21	0.2	0.15	0.11	
Total Kjeldahl Nitrogen	mg/L	0.98	0.34	0.33	0.23	
Nitrate-Nitrite	mg/L	0.063	0.066	ND	0.087	
Organic Nitrogen	mg/L	0.77	ND	ND	ND	
Phosphorus	mg/L	ND	ND	ND	ND	
Ortho-Phosphorus	mg/L	ND	ND	ND	ND	
Biological Oxygen Demand	mg/L	ND	ND	3.1	ND	
Hardness	mg/L	1,090	1,200	1,100	970	

Parameter	Units	Effluent Concentration ³			Calculated River Value ³				Water Quality	
		4/5/2019	4/9/2019	4/16/2019	4/22/2019	4/5/2019	4/9/2019	4/16/2019	4/22/2019	Standard ⁴
Arsenic	μg/L	ND	5.3	3.2	14.0	***	0.023	0.013	0.055	340
Cadmium	μg/L	0.56	ND	ND	ND	0.0005	***	***	***	1
Chromium ⁵	μg/L	ND	ND	ND	ND	***	***	***	***	16
Copper	μg/L	31.40	ND	ND	2.90	0.098	***	***	0.009	7
Lead	μg/L	3.60	ND	ND	1.60	0.006	***	***	0.003	30
Nickel	μg/L	11.0	14.0	8.4	11.0	0.046	0.064	0.037	0.046	260
Selenium ⁶	μg/L	9.3	4.8	6.9	16.0	0.049	0.025	0.036	0.084	5
Zinc	μg/L	32.5	28.0	ND	ND	0.096	0.096	***	***	65
Mercury	ng/L	ND	9.3	33.0	13.0	***	0.0091	0.0354	0.0149	1400

1 Tetra Tech verifies the correct laboratory analysis methods were used, any applicable permit limits have been met and other results are protective of Georgia EPD's water quality standards.

2 ND = Not Detected.

3 Calculated River Value shows what the total effluent concentration looks like once it has fully mixed in the receiving waterbody. This value is calculated as a dissolved concentration for an appropriate comparison to the numeric water quality criteria, which are also in the dissolved form. Consistent with Georgia EPD, non-detectable effluent concentrations are not translated into calculated river values.

4 Numeric Water Quality Criteria is the maximum concentration of a parameter (calculated at a default hardness of 50 mg/L as calcium carbonate) established for the receiving waterbody that will be protective of the designated use per Georgia EPD's rules and regulations. Calculated River Values less than these criteria are protective of the waterbody.

5 Numeric water quality criterion shown is for Hexavalent Chromium.

6 The numeric water quality criterion shown is the chronic (long-term) water quality criterion for selenium since this parameter does not have an acute (short-term) water quality criterion.

*** = Not Applicable

mg/L = milligrams per liter = parts per million; µg/L = micrograms per liter = parts per billion; ng/L = nanograms per liter = parts per trillion; SU = Standard Units; MGD = Million Gallons Day

Prepared by: FETRATECH Prepared by: FETRATECH Monthly Instream Results ¹ April 2019								
Power April 2019								
Etowah River ²								
Parameter ³	Units	4/9/2019 UpStream	4/9/2019 DownStream	4/16/2019 UpStream	4/16/2019 DownStream			
рН	SU	7.64	7.85	7.15	6.97			
TSS	mg/L	3.5	3.3	5.7	4.3			
O&G	mg/L	ND	ND	ND	ND			
Turbidity	NTU	3.6	3.8	3	4			
TDS	mg/L	61	55	44	45			
BOD	mg/L	ND	ND	ND	ND			
Arsenic	μg/L	ND	ND	ND	ND			
Cadmium	μg/L	ND	ND	ND	ND			
Chromium	μg/L	ND	ND	ND	ND			
Copper	μg/L	ND	ND	ND	ND			
Lead	μg/L	ND	ND	ND	ND			
Mercury	μg/L	0.00130	0.00130	0.00160	0.00150			
Nickel	μg/L	ND	ND	ND	ND			
Selenium	μg/L	ND	ND	ND	ND			
Zinc	μg/L	ND	ND	ND	ND			
Ammonia	mg/L	ND	ND	ND	ND			
TKN	mg/L	ND	ND	0.53	0.24			
Nitrate-Nitrite	mg/L	0.39	0.37	0.48	0.48			
Organic Nitrogen	mg/L	ND	ND	0.53	0.24			
Phosphorus	mg/L	ND	ND	ND	ND			
Ortho-phosphorus	mg/L	ND	ND	ND	ND			
Hardness	mg/L	37	36	21	20			

1 Tetra Tech verifies the correct laboratory analysis methods were used.

2 Etowah River measured 1000ft upstream and 1000ft downstream of the Final Plant Discharge (Outfall 01).

3 Metals results are total recoverable.

4 ND = Non-detect

mg/L = milligrams per liter = parts per million; μ g/L = micrograms per liter = parts per billion;

ng/L = nanograms per liter = parts per trillion; SU = Standard Units; MGD = Million Gallons Day