



Plant Bowen Monthly Dewatering Results¹ December 2017

Parameter	Units	Effluent Co	oncentration	Permit Limits	
Farameter		Minimum	Maximum	Daily Avg	Daily Max
Flow	MGD	0.0	0.29	***	***
рН	SU	6.50	7.60	6.0 - 9.0	
Total Suspended Solids	mg/L	6.0	6.0	30.0	100.0
Oil and Grease	mg/L	ND ²	ND	15.0	20.0

Parameter	Units	Measured Effluent Concentration		
		12/21/2017	12/27/2017	
Turbidity	NTU	3.1	4.5	
Total Dissolved Solids	mg/L	1720	1660	
Ammonia	mg/L	0.9	1.0	
Total Kjeldahl Nitrogen	mg/L	0.94	1.05	
Nitrate-Nitrite	mg/L	2.0	2.1	
Organic Nitrogen	mg/L	ND	ND	
Phosphorus	mg/L	ND	ND	
Ortho-Phosphorus	mg/L	ND	ND	
Hardness	mg/L	1190	1180	

Parameter	Units		ncentration ³	Calculated River Value 3		Water Quality Standard⁴
		12/21/2017	12/27/2017	12/21/2017	12/27/2017	
Arsenic	μg/L	ND	ND	***	***	340
Cadmium	μg/L	0.0037	0.0021	0.0000027	0.0000015	1
Chromium ⁵	μg/L	ND	ND	***	***	16
Copper	μg/L	ND	ND	***	***	7
Lead	μg/L	ND	ND	***	***	30
Nickel	μg/L	0.0404	0.0274	0.000190	0.000131	260
Selenium ⁶	μg/L	0.0077	0.0088	0.000040	0.000046	5
Zinc	μg/L	0.0404	0.0178	0.000146	0.000066	65
Mercury	ng/L	10.6	12.5	0.010	0.011	1400

- 1 Tetra Tech verifies the correct laboratory analysis methods were used, any applicable permit limits have been met and other results are protective of Georgia EPD's water quality standards.
- 2 ND = Not Detected.
- 3 Calculated River Value shows what the total effluent concentration looks like once it has fully mixed in the receiving waterbody. This value is calculated as a dissolved concentration for an appropriate comparison to the numeric water quality criteria, which are also in the dissolved form. Consistent with Georgia EPD, non-detectable effluent concentrations are not translated into calculated river values.
- Numeric Water Quality Criteria is the maximum concentration of a parameter (calculated at a default hardness of 50 mg/L as calcium carbonate) established for the receving waterbody that will be protective of the designated use per Georgia EPD's rules and regulations. Calculated River Values less than these criteria are protective of the waterbody.
- 5 Numeric water quality criterion shown is for Hexavalent Chromium.
- 6 The numeric water quality criterion shown is the chronic (long-term) water quality criterion for selenium since this parameter does not have an acute (short-term) water quality criterion.
- *** = Not Applicable