

## GROUNDWATER EXCEEDANCE NOTIFICATION 40 CFR § 257.95(g) PLANT MCDONOUGH-ATKINSON – ASH POND 1 (AP-1) GEORGIA POWER COMPANY

## **Federal CCR Rule**

The following Appendix IV constituent(s) were detected at statistically significant levels above the federal groundwater protection standards established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 CFR § 257.95(h).

- Cobalt
- Molybdenum

## State of Georgia CCR Rule

USEPA revised the Federal CCR Rule on July 30, 2018, updating groundwater protection standards for Cobalt, Lead, Lithium, and Molybdenum (See 40 CFR § 257.95(h)(2)). While these updated federal groundwater protection standards are expected to govern, the following Appendix IV constituent(s) were detected at statistically significant levels above the current state groundwater protection standards. See Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).

- Cobalt
- Molybdenum

Georgia Power will continue groundwater monitoring and reporting activities required by 40 CFR § 257.95.

Timothy I. Richards, PG

Associate and Senior Consultant

August 7, 2020

Date