



Plant McManus

Monthly Dewatering Results¹

February 2017

Prepared by: TETRA TECH

Parameter	Units	Effluent Concentration		Permit Limits	
		Minimum	Maximum	Daily Avg	Daily Max
Flow	MGD	0.00	0.64	***	***
pH	SU	6.53	8.41	6.0 - 9.0	
Total Suspended Solids	mg/L	8.5	9.0	30.0	100.0
Oil and Grease	mg/L	ND	ND	15.0	20.0

Parameter	Units	Measured Effluent Concentration	
		2/8/2017	2/13/2017
Turbidity	mg/L	4	7.3
Total Dissolved Solids	mg/L	1590	1440
Ammonia	mg/L	0.35	0.54
Total Kjeldahl Nitrogen	mg/L	1.4	1.3
Nitrate-Nitrite	mg/L	0.12	0.073
Organic Nitrogen	mg/L	1	0.74
Phosphorus	mg/L	0.12	ND
Ortho-Phosphorus	mg/L	0.0059	0.014
Hardness	mg/L	369	273

Parameter	Units	Effluent Concentration ³		Calculated River Value ³		Water Quality Standard ⁴
		2/8/2017	2/13/2017	2/8/2017	2/13/2017	
Arsenic	µg/L	4	3.6	2.14	1.94	69
Cadmium	µg/L	ND	ND	***	***	40
Chromium ⁵	µg/L	ND	ND	***	***	1100
Copper	µg/L	ND	ND	***	***	4.8
Lead	µg/L	ND	ND	***	***	210
Nickel	µg/L	ND	ND	***	***	74
Selenium	µg/L	3.1	1.3	3.10	1.30	290
Zinc	µg/L	ND	ND	***	***	90
Mercury	ng/L	1.06	0.92	0.34	0.29	1800

¹ Tetra Tech verifies the correct laboratory analysis methods were used, any applicable permit limits have been met and other results are protective of Georgia EPD's water quality standards.

² ND = Not Detected.

³ Calculated River Value shows what the total effluent concentration looks like once it has fully mixed in the receiving waterbody. This value is calculated as a dissolved concentration for an appropriate comparison to the numeric water quality criteria, which are also in the dissolved form. Consistent with Georgia EPD, non-detectable effluent concentrations are not translated into calculated river values.

⁴ Numeric Water Quality Criteria is the maximum concentration of a parameter (calculated at a default hardness of 50 mg/L as calcium carbonate) established for the receiving waterbody that will be protective of the designated use per Georgia EPD's rules and regulations. Calculated River Values less than these criteria are protective of the waterbody.

⁵ Numeric water quality criterion shown is for Hexavalent Chromium.

*** = Not Applicable

mg/L = milligrams per liter = parts per million; µg/L = micrograms per liter = parts per billion; ng/L = nanograms per liter = parts per trillion; SU = Standard Units; MGD = Million Gallons Day