

## **Plant McManus**

Prepared by:



## **Monthly Dewatering Results**<sup>1</sup>

## August 2017

Parameter	Units	Effluent Co	oncentration	Permit Limits	
		Minimum	Maximum	Daily Avg	Daily Max
Flow	MGD	0.00	0.95	***	***
рН	SU	6.78	8.12	6.0 - 9.0	
Total Suspended Solids	mg/L	13.0	13.5	30.0	100.0
Oil and Grease	mg/L	$ND^2$	ND	15.0	20.0

Parameter	Units	Measured Effluent Concentration		
		8/3/2017	8/7/2017	
Turbidity	mg/L	5.3	5.8	
Total Dissolved Solids	mg/L	2270	2230	
Ammonia	mg/L	0.78	0.54	
Total Kjeldahl Nitrogen	mg/L	1.3	1.1	
Nitrate-Nitrite	mg/L	0.064	ND	
Organic Nitrogen	mg/L	ND	0.61	
Phosphorus	mg/L	ND	ND	
Ortho-Phosphorus	mg/L	0.018	0.01	
Hardness	mg/L	555	445	

Parameter	Units	Effluent Concentration <sup>3</sup>		Calculated River Value <sup>3</sup>		Water Quality
		8/3/2017	8/7/2017	8/3/2017	8/7/2017	Standard <sup>4</sup>
Arsenic	μg/L	5.7	13.3	2.889	6.776	69
Cadmium	μg/L	ND	ND	***	***	40
Chromium <sup>5</sup>	μg/L	ND	ND	***	***	1100
Copper	μg/L	ND	ND	***	***	4.8
Lead	μg/L	ND	ND	***	***	210
Nickel	μg/L	9.1	1.8	3.650	0.729	74
Selenium	μg/L	1.1	ND	1.1	***	290
Zinc	μg/L	7.2	ND	1.945	***	90
Mercury	ng/L	0.924	3.46	0.3035	1.133	1800

- Tetra Tech verifies the correct laboratory analysis methods were used, any applicable permit limits have been met and other results are protective of Georgia EPD's water quality standards.
- 2 ND = Not Detected
- Calculated River Value shows what the total effluent concentration looks like once it has fully mixed in the receiving waterbody. This value is calculated as a dissolved concentration for an appropriate comparison to the numeric water quality criteria, which are also in the dissolved form. Consistent with Georgia EPD, non-detectable effluent concentrations are not translated into calculated river values.
- 4 Numeric Water Quality Criteria is the maximum concentration of a parameter established for the receving waterbody that will be protective of the designated use per Georgia EPD's rules and regulations. Calculated River Values less than these criteria are protective of the waterbody.
- 5 Numeric water quality criterion shown is for Hexavalent Chromium.
- \*\*\* = Not Applicable

 $mg/L = milligrams per liter = parts per million; \mu g/L = micrograms per liter = parts per billion; ng/L = nanograms per liter = parts per trillion; SU = Standard Units; MGD = Million Gallons Day$