257.83 (b) (2)	REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT					
	FACILITY NAME: Plant Scherer Ash Pond					
	OWNER/OPERATOR OF FACILITY: Georgia Power Company					
	INSPECTION DATE: August 27, 2015					
	INSPECTING ENGINEER: Todd L. Barber, PE (GA Reg. # PE025787)					
	Based on the results of my inspection and review of the data provided, it is my professional					
	opinion that the report has been completed in accordance with 40 CFR 257.83(b).					
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE			N/A*		
	SINCE THE PREVIOUS ANNUAL INSPECTION?					
	(IF YES, DESCRIBE):					
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENT	ATION		SEE ATTACHED PLAN		
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION			N/A*		
	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATIO IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION					
	MIN. DEPTH: N/A*	MAX. DEPTH: N/A* MAX. ELEVATION: N/A*		PRESENT DEPTH:		
	·			Up to 62.5'		
	MIN. ELEVATION: N/A*			PRESENT.		
				ELEVATION: 495.5'		
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.					
	MIN. DEPTH: N/A*	MAX. DEPTH: N/A*		PRESENT DEPTH:		
				Up to 87'		
(iv)	MIN. ELEVATION: N/A*	MAX. ELE	VATION:		PRESENT	
		N/A*		ELEVATION: 497'**		
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING			29,846,667***		
	STRUCTURE AT TIME OF INSPECTION (yd-7					
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER	R AND	WATER:		CCR:	
(0)	CCR AT TIME OF INSPECTION (yd³) 14,612,84		5***	15,233,822***		
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL					
	WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO				NO	
	DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND					
	APPURTENANT STRUCTURES?					
	(IF YES, DESCRIBE):					
	(ii 120) 0200(ii02).					
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY			21/24		
	OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?				N/A*	
	(IF YES, DESCRIBE):					

* This is the first 'Annual inspection by a qualified professional engineer' performed in accordance with 40 CFR Part 257.83. This information will be included in subsequent annual inspection reports.

** Highest elevation of CCR at approximately 515' is at several locations in south part of pond, not at location of deepest CCR

***Cubic yard estimates derived by qualified personnel from available information.

