

GROUNDWATER EXCEEDANCE NOTIFICATION 40 C.F.R. PART 257.95(g) PLANT YATES AP-3, A, B, B' and R6 CCR Landfill GEORGIA POWER COMPANY

The following Appendix IV constituent(s) were detected at statistically significant levels above groundwater protection standards established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 C.F.R. 257.95(h) and Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).

Federal CCR Rule

- Cobalt
- Beryllium
- Selenium

State of Georgia CCR Rule

- Cobalt
- Beryllium
- Selenium

Georgia Power will continue groundwater monitoring and reporting activities required by 40 CFR §257.95.

elfrusc

Geoffrey Gay, P.E. Principal Environmental Engineer

<u>August 7, 2020</u> Date